

Process Safety Management of Highly Hazardous & Explosive Chemicals



Process Hazard Analysis 29CFR1910.119(e)


Process Hazard Analysis (PHA)


1910.119(e)


The employer shall perform an initial process hazard analysis (hazard evaluation) on processes covered by this standard. The process hazard analysis shall be appropriate to the complexity of the process and shall identify, evaluate, and control the hazards involved in the process. Employers shall determine and document the priority order for conducting process hazard analyses based on a rationale which includes such considerations as extent of the process hazards, number of potentially affected employees, age of the process, and operating history of the process.

Process Hazard Analysis (PHA)

- Process Hazard Analysis is a specific tool that:
- Assists in identifying possible deviations within a system
- Determines if those deviations could present undesired consequences
- If so, assesses degree and likelihood of consequence
- Provides mechanism for modifying the system if likelihood of consequence is not "tolerable"









Remember

- Before conducting PHA, compile and maintain
 - Chemical Hazards Information
 - Process Technology Information
 - Equipment Information
- Kept for the lifetime of the process
- Updated whenever changes other than “replacement in kind” are made or whenever necessary even when replacement in kind
- PSI applicable to various employees’ jobs must be shared with those employees (operators, maintenance, contractors)



You Developed a List of Equipment Locations & Assets

The PHA Must Address:

- Equipment in the process
- Hazards of the process
- Identification of previous incidents
- Engineering and administrative controls
- Consequences of failure
- Facility siting
- Human factors
- Qualitative evaluation of Safety and Health effects
- Consequences of deviation
- Steps required to correct or avoid deviation

Facility Siting:

Facility Siting -

—Texas City, TX 1947. LEARNING: Confinement added to strength of explosion strength

—Flixborough, UK 1974 Community fatalities and damage.
LEARNING: Plants are getting large enough to impact the neighbors

—Norco, LA 1988 Control room in center of unit destroyed.
LEARNING: Control Buildings should be designed for VCEs

—Pasadena, TX 1989 Muster location building destroyed. **LEARNING:**
Emergency Response should consider Facility Siting

—BP, Texas City, TX 2005 **LEARNING:** Portable buildings are weaker than previously thought, unnecessary people too close to unit, an *Industry Standard for Portable Buildings was developed*

—Total, Buncefield, UK 2006 *LEARNING: Trees can act as congestion*

Facility Siting

■ Facility Siting – with respect to existing plants, “siting” does not refer to the site of the plant in relation to the surrounding community. It refers, rather, to the location of various components within the establishment. This includes, but is not limited to:

- Permanent and temporary employee-occupied buildings, including trailers, that expose employees by virtue of their location, to potential hazards such as fires, explosions, overpressures, exposure to toxic or corrosive materials, or that risk being damaged by other process equipment, etc.
- Cooling towers
- Flares and other vents
- Emergency access
- Piperacks
- Emergency response facilities
- Fire pumps
- Emergency isolation valves, etc.

PHA Methodologies

Must select a process hazard analysis (PHA) method

- What-If;
- Checklist;
- What-If/Checklist;
- Hazard and Operability Study (HAZOP); 
- Failure Mode and Effects Analysis (FMEA);
- Fault Tree Analysis
- An appropriate equivalent methodology

Let's Choose HAZOP to Study

The Most Common Method used for PHAs



PHA - HAZOP Process

- The PHA process is based on the principle that a team approach to hazard analysis will identify more problems than when individuals working separately combine results.
- The HAZOP team is made up of individuals with varying backgrounds and expertise.
- The expertise is brought together during HAZOP sessions and through a collective brainstorming effort that stimulates creativity and new ideas, a thorough review of the process under consideration is made.

PHA - HAZOP Process

- The HAZOP team focuses on specific portions of the process called "nodes".
- Generally these are identified from the P&ID of the process before the study begins.
- A process parameter is identified, say flow, and an intention is created for the node under consideration.
- Then a series of guidewords is combined with the parameter "flow" to create a deviations.
- For example, the guideword "no" is combined with the parameter flow to give the deviation "no flow".

HAZOP Team Leader

- The PHA team leader works with the PHA coordinator in defining the scope of the analysis and selection of team members.
- Directs the team members in gathering of process safety information prior to the start of the study.



HAZOP Team Leader

- Plans the study with the PHA coordinator and schedules team meetings
- Leads the team in the analysis of the selected process
- Keeps team members focused on discovering hazards associated with the process
- Directs the team scribe in recording the results of the teams findings



HAZOP Resources

- The engineering experts assigned to the PHA may include some or all of the following:
 - project engineer
 - controls engineer
 - instrument engineer
 - electrical engineer
 - mechanical engineer
 - safety engineer
 - quality assurance engineer
 - maintenance engineer or technician
 - corrosion/materials engineer



HAZOP Guidewords & Parameters

- The HAZOP process creates deviations from the process design intent by combining guide words (No, more, less, etc.) with process parameters resulting in a possible deviation from design intent
- Application of parameters will depend on the type of process being considered, the equipment in the process and the process intent

- **Guidewords:**
 - No
 - More
 - Less
 - As Well As
 - Reverse
 - Other Than

- **Parameters:**
 - Flow
 - Temperature
 - Pressure
 - Composition
 - Phase
 - Level
 - Relief
 - Instrumentation

HAZOP

Deviations

- A deviation is considered realistic if there are sufficient causes to believe the deviation can occur
- Team judgment is used to decide whether to include events with a very low probability of occurring
- What could go wrong?



HAZOP

Three General Causes of Deviations

- Human Error - acts of omission or commission by an operator, designer, constructor or other person creating a hazard that could possibly result in a release of hazardous or flammable material



HAZOP

Deviation Causes

- Equipment failure in which a mechanical, structural or operating failure results in the release of hazardous or flammable material.



HAZOP

Deviation Causes

- External Events in which items outside the unit being reviewed affect the operation of the unit to the extent that the release of hazardous or flammable material is possible.



HAZOP

Consequences

- Identify scenarios which could result in undesired impacts
 - Loss of primary containment (LOPC)
 - Fires, explosions, toxic releases
 - Employee exposures
 - Injuries
 - Environmental issues
 - Operability issues
 - Quality concerns
- How bad could it be?



HAZOP

Consequences

- Help to determine a risk ranking in HAZOPs where multiple deviations are uncovered
- Help make the determination as to whether a particular deviation results in an operability problem or hazard.



HAZOP

Frequency

- Team must assess the likelihood of an undesired deviation/consequence
- Most commonly qualitative
 - Frequent
 - Often
 - Rare
 - Unlikely
 - Never
- How likely is it to occur?



HAZOP

Safeguards


- Safeguards should be assessed whenever the team determines that a consequence is “of interest”. (i.e. of sufficient impact and/or credibility)



HAZOP

Safeguards - Three Classifications


- Those systems, **engineered designs and written procedures** that are designed to prevent a catastrophic release of hazardous or flammable material.



HAZOP

Safeguards - Three Classifications

- Those systems that are designed to detect and give early warning following the initiating cause of a release of hazardous or flammable material.



HAZOP

Safeguards - Three Classifications




- Those systems or written procedures that mitigate the consequences of a release of hazardous or flammable material.



PHA Risk Analysis

Risk Ranking Matrix

		Severity				
		Negligible	Minor	Major	Severe	Disastrous
Likelihood	Frequent					
	Likely					Significant Risk
	Unlikely					
	Rare					
	Extraordinary					



HAZOP Recommendations

- Prioritize recommendations
- Establish a plan to track to completion
- Management review of progress



Using HAZOP

Let's Explore a PHA Process

Process Hazard Analysis

- A PHA must be performed on each asset of the covered process:
- A PHA from Block Diagram to P&ID to every equipment asset to determine what might happen if an element of the covered process fails



Example: Node 2, Flow

Session: (1) 01/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

Node

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8	No recommendation
	2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB	2.1.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB	3	4	8	2.1.1. "Investigate the potential for overpressure in expansion tanks and pressure setting of the rupture disk"
	3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.2. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		2.1.2. "Verify Chlorin requirements for vent valves with design & review"
				3.1.3. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		No further recommendation

Example: Node 2, Flow

Session: (1) 01/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

Asset

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8	No recommendation
	2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB	2.1.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB	3	4	8	2.1.1. "Investigate the potential for overpressure in expansion tanks and pressure setting of the rupture disk"
	3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.2. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		2.1.2. "Verify Chlorin requirements for vent valves with design & review"
				3.1.3. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		No further recommendation

Example: Node 2, Flow

Session: (1) 01/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

Deviation

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8	No recommendation
	2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB	2.1.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB	3	4	8	2.1.1. "Investigate the potential for overpressure in expansion tanks and pressure setting of the rupture disk"
	3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.2. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		2.1.2. "Verify Chlorin requirements for vent valves with design & review"
				3.1.3. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9		No further recommendation

Example: Node 2, Flow

Session: (1) 07/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL01-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Falling closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8		No recommendation
		2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between -VUQA and VUQB -PCVOASC and PCVGASB (downstream of vaporizer)	3	4	8		
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Falling closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No further recommendation

Causes

Example: Node 2, Flow

Session: (1) 07/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL01-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Falling closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8		No recommendation
		2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between -VUQA and VUQB -PCVOASC and PCVGASB (downstream of vaporizer)	3	4	8		
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Falling closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No further recommendation

Consequences

Example: Node 2, Flow

Session: (1) 07/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL01-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Falling closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8		No recommendation
		2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between -VUQA and VUQB -PCVOASC and PCVGASB (downstream of vaporizer)	3	4	8		
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Falling closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No further recommendation

Safeguards

Example: Node 2, Flow

Session: (1) 07/02/2000
Node: C2 liquid to vaporizer
Drawing: CL01-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

GW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8		No recommendation
		2. Control system incorrectly activates shutdown for "niture" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.2.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB, and P-PCV04SC and P-PCV04BB (downstream of vaporizer)	3	4	8		
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB, and P-PCV04SC and P-PCV04BB (downstream of vaporizer)	4	9			2.1.1. "Investigate the potential for overpressure in the expansion tanks and pressure setting of the rupture disk."
			3.1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	2.1.2. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			2.1.2. "Verify Chlorin requirements for vent valves with design o
				3.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No further recommendation

Risk Factors

Example: Node 2, Flow

Session: (1) 07/02/2000
Node: C2 liquid to vaporizer
Drawing: CL01-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

GW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8		No recommendation
		2. Control system incorrectly activates shutdown for "niture" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.2.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB, and P-PCV04SC and P-PCV04BB (downstream of vaporizer)	3	4	8		
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB, and P-PCV04SC and P-PCV04BB (downstream of vaporizer)	4	9			2.1.1. "Investigate the potential for overpressure in the expansion tanks and pressure setting of the rupture disk."
			3.1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	2.1.2. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			2.1.2. "Verify Chlorin requirements for vent valves with design o
				3.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No further recommendation

Recommendations

Example: Node 2, Flow

Session: (1) 07/02/2000
Node: C2 liquid to vaporizer
Drawing: CL01-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

GW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No recommendation
		1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity	3	4	8		No recommendation
		2. Control system incorrectly activates shutdown for "niture" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up	1.2.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB, and P-PCV04SC and P-PCV04BB (downstream of vaporizer)	3	4	8		
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB, and P-PCV04SC and P-PCV04BB (downstream of vaporizer)	4	9			2.1.1. "Investigate the potential for overpressure in the expansion tanks and pressure setting of the rupture disk."
			3.1.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	2.1.2. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			2.1.2. "Verify Chlorin requirements for vent valves with design o
				3.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	9			No further recommendation

Continue the PHA Process UNTIL...

Example: Node 2, Flow

Session: (1) 01/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

GW DEVIATION CAUSES CONSEQUENCES SAFEGUARDS S L R REF# RECOMMENDATION

No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C₂ piping if liquid-filled, closed piping heats up	1.1.1. Failing closed, or accidentally closing a single valve will not result in overpressure since line is open to either end	4	9	No recommendation	
		1.2. Potential overpressure of C₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C₂ service are provided with a port to vent the ball cavity	3	4	No recommendation	
		2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB -PCVOASC and PCVQASB (downstream of vaporizer)	3	4	No recommendation	
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C₂ piping if liquid-filled, closed piping heats up	3.1.1. Failing closed, or accidentally closing a single valve will not result in overpressure since line is open to either end	4	9	No further recommendation	

Example: Node 2, Flow

Session: (1) 01/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

GW DEVIATION CAUSES CONSEQUENCES SAFEGUARDS S L R REF# RECOMMENDATION

No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C₂ piping if liquid-filled, closed piping heats up	1.1.1. Failing closed, or accidentally closing a single valve will not result in overpressure since line is open to either end	4	9	No recommendation	
		1.2. Potential overpressure of C₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C₂ service are provided with a port to vent the ball cavity	3	4	No recommendation	
		2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB -PCVOASC and PCVQASB (downstream of vaporizer)	3	4	No recommendation	
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C₂ piping if liquid-filled, closed piping heats up	3.1.1. Failing closed, or accidentally closing a single valve will not result in overpressure since line is open to either end	4	9	No further recommendation	

Example: Node 2, Flow

Session: (1) 01/02/2000
Node: (2) C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer

GW DEVIATION CAUSES CONSEQUENCES SAFEGUARDS S L R REF# RECOMMENDATION

No	No Flow	1. Control valve CV-32 fails closed	1.1. Interruption to production operation due to deviation of C₂ piping if liquid-filled, closed piping heats up	1.1.1. Failing closed, or accidentally closing a single valve will not result in overpressure since line is open to either end	4	9	No recommendation	
		1.2. Potential overpressure of C₂ piping if liquid-filled, closed piping heats up	1.1.2. Operator response to a shutdown of the system would be immediate	1.2.1. All valves (ball valves) in liquid C₂ service are provided with a port to vent the ball cavity	3	4	No recommendation	
		2. Control system incorrectly activates shutdown for "hazard" condition	2.1. Potential overpressure of C₂ piping if liquid-filled, closed piping heats up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB -PCVOASC and PCVQASB (downstream of vaporizer)	3	4	No recommendation	
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C₂ piping if liquid-filled, closed piping heats up	3.1.1. Failing closed, or accidentally closing a single valve will not result in overpressure since line is open to either end	4	9	No further recommendation	

Example: Node 2, Flow							
Session: (1) 07/02/2000		Revision: 0					
Node: C2 liquid to vaporizer		Drawing: CL01-07-66					
Parameter: Flow		Intention: Flow approximately 1-5 bushmin of liquid chlorine, at 100-150 psig, from the racker to the vaporizer.					
OW CAUSE		CAUSES CONSEQUENCES SAFEGUARDS S L R REF# RECOMMENDATION					
No Flow		1. Control valve CV-32 fails closed  1.1. Interruption to production operation due to deviation of C ₂ piping if liquid-filled, closed piping heats up 1.2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up					
			1.1.1. Falling closed, or accidentally closing a single valve will not result in overpressure since line is open to either end 1.1.2. Operator response to a shutdown of the system would be immediate 1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity 1.2.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB, V-PCVOASC and PCVQASB (downstream of vaporizer)				
			3 4 8 3 4 8 3 4 9				
All Causes							
2. Control system incorrectly activates shutdown for "hazard" condition		2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heats up					
		2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between V-ULQA and V-ULQB, V-PCVOASC and PCVQASB (downstream of vaporizer)					
		3 4 8					
3. Control valve closes due to incorrect signal or setting		3.1. Interruption to production operation due to deviation of C ₂ piping if liquid-filled, closed piping heats up					
		3.1.1. Falling closed, or accidentally closing a single valve will not result in overpressure since line is open to either end					
		3 4 9					
3.1.1. "Investigate the of the rupture disks i expansion tanks and pressure setting of the rupture disk"							
3.1.2. "Verify Chlorin requirements for ver valves with design o valves"							
3.1.3. "No further recomme							
3.1.4. "No further recomme							
3.1.5. "No further recomme							
3.1.6. "No further recomme							
3.1.7. "No further recomme							
3.1.8. "No further recomme							
3.1.9. "No further recomme							
3.1.10. "No further recomme							
3.1.11. "No further recomme							
3.1.12. "No further recomme							
3.1.13. "No further recomme							
3.1.14. "No further recomme							
3.1.15. "No further recomme							
3.1.16. "No further recomme							
3.1.17. "No further recomme							
3.1.18. "No further recomme							
3.1.19. "No further recomme							
3.1.20. "No further recomme							
3.1.21. "No further recomme							
3.1.22. "No further recomme							
3.1.23. "No further recomme							
3.1.24. "No further recomme							
3.1.25. "No further recomme							
3.1.26. "No further recomme							
3.1.27. "No further recomme							
3.1.28. "No further recomme							
3.1.29. "No further recomme							
3.1.30. "No further recomme							
3.1.31. "No further recomme							
3.1.32. "No further recomme							
3.1.33. "No further recomme							
3.1.34. "No further recomme							
3.1.35. "No further recomme							
3.1.36. "No further recomme							
3.1.37. "No further recomme							
3.1.38. "No further recomme							
3.1.39. "No further recomme							
3.1.40. "No further recomme							
3.1.41. "No further recomme							
3.1.42. "No further recomme							
3.1.43. "No further recomme							
3.1.44. "No further recomme							
3.1.45. "No further recomme							
3.1.46. "No further recomme							
3.1.47. "No further recomme							
3.1.48. "No further recomme							
3.1.49. "No further recomme							
3.1.50. "No further recomme							
3.1.51. "No further recomme							
3.1.52. "No further recomme							
3.1.53. "No further recomme							
3.1.54. "No further recomme							
3.1.55. "No further recomme							
3.1.56. "No further recomme							
3.1.57. "No further recomme							
3.1.58. "No further recomme							
3.1.59. "No further recomme							
3.1.60. "No further recomme							
3.1.61. "No further recomme							
3.1.62. "No further recomme							
3.1.63. "No further recomme							
3.1.64. "No further recomme							
3.1.65. "No further recomme							
3.1.66. "No further recomme							
3.1.67. "No further recomme							
3.1.68. "No further recomme							
3.1.69. "No further recomme							
3.1.70. "No further recomme							
3.1.71. "No further recomme							
3.1.72. "No further recomme							
3.1.73. "No further recomme							
3.1.74. "No further recomme							
3.1.75. "No further recomme							
3.1.76. "No further recomme							
3.1.77. "No further recomme							
3.1.78. "No further recomme							
3.1.79. "No further recomme							
3.1.80. "No further recomme							
3.1.81. "No further recomme							
3.1.82. "No further recomme							
3.1.83. "No further recomme							
3.1.84. "No further recomme							
3.1.85. "No further recomme							
3.1.86. "No further recomme							
3.1.87. "No further recomme							
3.1.88. "No further recomme							
3.1.89. "No further recomme							
3.1.90. "No further recomme							
3.1.91. "No further recomme							
3.1.92. "No further recomme							
3.1.93. "No further recomme							
3.1.94. "No further recomme							
3.1.95. "No further recomme							
3.1.96. "No further recomme							
3.1.97. "No further recomme							
3.1.98. "No further recomme							
3.1.99. "No further recomme							
3.1.100. "No further recomme							
3.1.101. "No further recomme							
3.1.102. "No further recomme							
3.1.103. "No further recomme							
3.1.104. "No further recomme							
3.1.105. "No further recomme							
3.1.106. "No further recomme							
3.1.107. "No further recomme							

Example: Node 2, Flow

Session: (1) 01/02/2000
Node: C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushels of liquid chlorine, at 100-150 psig, from the racker to the vaporizer.

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed 2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heads up	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end 1.1.2. Operator response to a shutdown of the system would be immediate 1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity 1.2.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between GA-04 and GA-05, and between GA-05 and PCV04SC and PCV04BB (downstream of vaporizer)	3	4	8		No recommendation	
		2. Control system incorrectly activates shutdown for "rupture" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heads up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between GA-04 and GA-05, and between GA-05 and PCV04SC and PCV04BB (downstream of vaporizer)	3	4	8		2.1.1. "Investigate the potential for overpressure in expansion tanks and propose setting CTF for the rupture disk 2.1.2. Verify Chloros requirements for vent valves with design & review"
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	4	9		No further recommendation

WPS P1 for Help

Example: Node 2, Flow

Session: (1) 01/02/2000
Node: C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushels of liquid chlorine, at 100-150 psig, from the racker to the vaporizer.

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed 2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heads up	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end 1.1.2. Operator response to a shutdown of the system would be immediate 1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity 1.2.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between GA-04 and GA-05, and between GA-05 and PCV04SC and PCV04BB (downstream of vaporizer)	3	4	8		No recommendation	
		2. Control system incorrectly activates shutdown for "rupture" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heads up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between GA-04 and GA-05, and between GA-05 and PCV04SC and PCV04BB (downstream of vaporizer)	3	4	8		2.1.1. "Investigate the potential for overpressure in expansion tanks and propose setting CTF for the rupture disk 2.1.2. Verify Chloros requirements for vent valves with design & review"
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	4	9		No further recommendation

WPS P1 for Help

Example: Node 2, Flow

Session: (1) 01/02/2000
Node: C2 liquid to vaporizer
Drawing: CL07-07-66
Parameter: Flow
Intention: Flow approximately 1-5 bushels of liquid chlorine, at 100-150 psig, from the racker to the vaporizer.

OW	CAUSE	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATION	
No	No Flow	1. Control valve CV-32 fails closed 2. Potential overpressure of C ₂ piping if liquid-filled, closed piping heads up	1.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end 1.1.2. Operator response to a shutdown of the system would be immediate 1.2.1. All valves (ball valves) in liquid C ₂ service are provided with a port to vent the ball cavity 1.2.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between GA-04 and GA-05, and between GA-05 and PCV04SC and PCV04BB (downstream of vaporizer)	3	4	8		No recommendation	
		2. Control system incorrectly activates shutdown for "rupture" condition	2.1. Potential overpressure of C ₂ piping if liquid-filled, closed piping heads up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between GA-04 and GA-05, and between GA-05 and PCV04SC and PCV04BB (downstream of vaporizer)	3	4	8		2.1.1. "Investigate the potential for overpressure in expansion tanks and propose setting CTF for the rupture disk 2.1.2. Verify Chloros requirements for vent valves with design & review"
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption to production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Failing closed, or accidentally closing, a single valve will not result in overpressure since line is open to either end	4	4	9		No further recommendation

WPS P1 for Help

Are Completed for

1. Every asset of...
2. Every P&ID of...
3. Every Block Diagram Section...
4. Of the Entire Covered Process Is Complete

Don't Forget to
Perform PHA on
Operating Procedures

Example: Node 2, Flow


Revision: 0

System: (1) 87002000
Reactor to vaporizer
Drawing: CL07-07-68
Parameter: Flow
Baseline: Flow approximately 1-5 lb/min of liquid chlorine, at 100-150 psig, from the railcar to the vaporizer.

No	DEVIATION	CAUSES	CONSEQUENCES	SAFEGUARDS	S	L	R	REF#	RECOMMENDATIONS
					4	9	3	4	8
1	No Flow	1. Control valve CV-32 fails closed	1.1. Failure to maintain normal operation due to deviation of C ₂ flow from setpoint causing control system to shut down process	1.1.1. A single valve will not result in overpressure since line is open to either end					No recommendation
		1.2. Potential overpressure of C ₂ stems if liquid filled, closed by heat up	1.2.1. All valves (ball valves) in liquid C ₂ lines are provided with a port to vent the ball valve	1.2.2. Rupture disk discharging to expansion tanks are provided for the section of the piping between 3-LV0001 and 3-LV0002 (downstream of vaporizer)					No recommendation
		Potential overpressure of C ₂ stems if liquid filled, closed by heat up	2.1.1. Rupture disk discharging to expansion tanks are provided for the section of the piping between 3-LV0001 and 3-LV0002 (downstream of vaporizer)	2.1.2. Falling closed, or accidentally closing, a valve will result in overpressure since line is open to either end					2.1.1. Investigate the potential for overpressure in expansion tanks and propose a safety cut-off for the rupture disk
		3. Control valve closes due to incorrect signal or setting	3.1. Interruption in production operation due to deviation of C ₂ flow from setpoint causing	3.1.1. Falling closed, or accidentally closing, a valve will result in overpressure since line is open to either end					3.1.2. Verify Chlorine requirements for vent valves with design o
									No further recommendation

**This Process Might
Entail Thousands of
Covered Process
assets & Phases**

**...and Take Months /
Years to Complete**



Layer of Protection Analysis



**Basics of Safety Instrumented Systems
and LOPA**

What if Recommendations aren't easily identified?

How do you know when you have enough recommendations?

Consider Layers of Protection Analysis (LOPA)

Layer of Protection Analysis (LOPA)

• Why is LOPA useful?

- Turns out, PHA teams (and humans in general) are pretty terrible at qualitative likelihood assessment
- Personal risk tolerance is unavoidable and is a function of too many variables (personal experiences, etc.)
- Need a more quantitative approach for particularly high consequence or high qualitative risk scenarios
- LOPA uses failure data to assess the likelihood of both the initiating event AND credited safeguards to determine if risk is tolerable.

Layers of Protection Analysis (LOPA)

Key Definitions:

- **Initiating Event** – The event that initiates the scenario leading to the undesired consequence. (valve fails)
- **Frequency** – the number of occurrences per unit of time (*normally per year, but all units must match*)
- **Independent Protection Layer (IPL)** – a device, system, or action that is capable of preventing the undesired consequence regardless of the initiating event or the action of any other protection layer associated with the scenario. **Independent** means the performance of the protection layer is not affected by failures of other protection layers. The **effectiveness** and independence of an IPL should be **auditable**.
- **Probability of Failure on Demand (PFD)** – the probability that a system will fail to perform a specified function on demand.

Layers of Protection Analysis (LOPA)

□ **Generally**

1. Company determines the consequence severity or risk level for screening scenarios
2. Identify frequency of initiating event (IEF)
3. Identify the Independent Protection Layers (IPLs) and estimate the probability of failure on demand (PFD) of each IPL
4. Calculate the scenario frequency with all IPLs in place (multiply probabilities because all must occur for consequence)
IEF X PFD₁ X PFD₂ X.....
5. Compare the estimated risk to company risk tolerance criteria. Make recommendations to lower risk if needed.


5. Compare the estimated risk to c

Make recommendations to lower risk if needed.

What is a Safety Instrumented System (SIS)?

- An SIS is designed to:

- Respond to conditions in the plant which may be hazardous in themselves or,
- If no action was taken, could eventually give rise to a hazard, and
- To respond to these conditions by taking defined actions that either prevent the hazard or mitigate the hazard consequences.



Standards Bodies that Define Good Engineering Practice for Safety Instrumented Systems

- ISA, Instrumentation Systems and Automation Society
- IEC, International Electrotechnical Commission
 - IEC 61508
 - IEC 61511
- NFPA
- ISA 84.01-2003
- API
- ASME

Safety Instrumented System Standards

IEC 61508 - "Functional Safety: Safety Related Systems"
Current version released 1999
Under revision for next release 2005

IEC 61511 - "Functional Safety: Safety Instrumented Systems for the Process Industry Sector"
Published 2003


ISA 84.01-2003 - "Instrumented Systems for the Process Industry Sector"
Identical to IEC 61511 with inclusion of grandfather clause
To be published October 2003

Safety Integrity Level (SIL)

SIL	PFDavg	Risk Reduction	Availability (%)
4	10^{-4} to 10^{-5}	10,000 to 100,000	99.99 to 99.999
3	10^{-3} to 10^{-4}	1,000 to 10,000	99.9 to 99.99
2	10^{-2} to 10^{-3}	100 to 1,000	99 to 99.9
1	10^{-1} to 10^{-2}	10 to 100	90 to 99

Design SIF

- Justify selection of devices
- Document the safety requirements specification
- Design SIFs to achieve Safety Integrity Level.





- Verify
 - Safety Integrity Level
 - Fault tolerance
- Commissioning
 - Install SIFs per design documents
- Functional safety assessment
 - Make sure all documents are in place and all hazards analysis items are addressed.
- Validation
 - Test SIFs to ensure that they have desired functionality

Basically, You Have to Honor & Marry Your SIS

- Layer of Protection Analysis (LOPA)
- Why is LOPA useful?
 - Turns out, PHA teams (and humans in general) are pretty terrible at qualitative likelihood assessment
 - Personal risk tolerance is unavoidable and is a function of too many variables (personal experiences, etc.)
 - Need a more quantitative approach for particularly high consequence or high qualitative risk scenarios
 - LOPA uses failure data to assess the likelihood of both the initiating event AND credited safeguards to determine if risk is tolerable.

- LOPA is NOT a “stand alone” risk analysis tool
 - LOPA is a *complement* or “*sharper pencil*” to hazard identification tools
 - LOPA depends on PHAs or other methods to identify the scenario (cause/consequence pair) and to identify safeguards

Layers of Protection Analysis (LOPA)

❑ Generally,

1. Company determines the consequence severity or risk level for screening scenarios
2. Identify frequency of initiating event, taking into account enabling conditions and/or conditional modifiers (if desired)
3. Identify the Independent Protection Layers (IPLs) and estimate the probability of failure on demand (PFD) of each IPL
4. Calculate the scenario frequency with all IPLs in place (multiply probabilities because all must occur for consequence)
5. Compare the estimated risk to company risk tolerance criteria. Make recommendations to lower risk if needed.

73 |

Layers of Protection Analysis (LOPA)

❑ Key Definitions

- **Initiating Event** – The event that initiates the scenario leading to the undesired consequence. (valve fails)
- **Frequency** – the number of occurrences per unit of time (*normally per year, but all units must match*)
- **Independent Protection Layer (IPL)** – a device, system, or action that is capable of preventing the undesired consequence regardless of the initiating event or the action of any other protection layer associated with the scenario. Independent means the performance of the protection layer is not affected by failures of other protection layers. The effectiveness and independence of an IPL should be auditable.
- **Probability of Failure on Demand (PFD)** – the probability that a system will fail to perform a specified function on demand.

74 |

Layer of Protection Analysis (LOPA)

- Must establish/identify and consistently apply:
 - Initiating event frequencies
 - Conditional modifiers
 - Ignition likelihood
 - Component failure data
 - Rules for human failure frequency
 - Tolerable risk criteria

75 |

Layer of Protection Analysis (LOPA)					
■ Example of Initiating Event Frequencies (per year)					
Initiating Event	Company 1	Company 2	Company 3	CCPS	Comments
BPCS instrument loop failure - clean service	1×10^{-1}	1×10^{-1}	1×10^{-1}	1×10^{-1}	
Other - relief valve or rupture disc opens early	1×10^{-2}		1×10^{-2}	1×10^{-2}	
Other - mechanical failures hoses: no moving parts - no vibration	1×10^{-2}	1×10^{-2}			Requires hose inspection, compatible construction, proper connections
Other - pressure regulator failure - clean service, periodic maintenance	1×10^{-2}				
Other - pump failure, single pump	1×10^{-1}	1×10^{-1}			
Other - pressure vessel residual failure	1×10^{-6}				This assumes a properly designed and operated vessel without other process deviations in play. Other failure modes such as stress corrosion, corrosion, glass lining damage, etc., must be considered separately.

76 |

Layer of Protection Analysis (LOPA)		
Typical Frequency Values, f_i , Assigned to Initiating Events		
Initiating Event	Frequency Range from Literature (per year)	Example of a Value Chosen by a Company for Use in LOPA (per year)
Pressure vessel residual failure	10^{-3} to 10^{-7}	1×10^{-6}
Unloading/loading hose failure	1 to 10^{-1}	1×10^{-1}
BPCS instrument loop failure <small>Note: IEC 61511 limit is more than 1×10^{-6}/hr or 8.76×10^{-5}/yr (IEC, 2001)</small>	1 to 10^{-2}	1×10^{-1}
Regulator failure	1 to 10^{-1}	1×10^{-1}
Small external fire (aggregate causes)	10^{-1} to 10^{-2}	1×10^{-1}
Large external fire (aggregate causes)	10^{-2} to 10^{-3}	1×10^{-2}
LOTO (lock-out tag-out) procedure* failure *overall failure of a multiple-element process	10^{-3} to 10^{-4} per opportunity	1×10^{-3} per opportunity
Operator failure (to execute routine procedure, assuming well trained, unstressed, not fatigued)	10^{-1} to 10^{-3} per opportunity	1×10^{-2} per opportunity


Layer of Protection Analysis..., Wiley, CCPS, 2001

Layer of Protection Analysis (LOPA)			
Examples of Active IPLs			
IPL	Comments	PFD from Literature and Industry	PFD Used in This Book (For screening)
Relief valve	Prevents system exceeding specified overpressure. Effectiveness of this device is sensitive to service and experience.	$1 \times 10^{-1} - 1 \times 10^{-3}$	1×10^{-2}
Rupture disc	Prevents system exceeding specified overpressure. Effectiveness can be very sensitive to service and experience.	$1 \times 10^{-1} - 1 \times 10^{-3}$	1×10^{-2}
Basic Process Control System	Can be credited as an IPL if not associated with the initiating event being considered (see also Chapter 11). (See IEC 61508 (IEC, 1998) and IEC 61511 (IEC, 2001) for additional discussion.)	$1 \times 10^{-1} - 1 \times 10^{-2}$ ($>1 \times 10^{-3}$ allowed by IEC)	1×10^{-1}
Safety Instrumented Functions (Interlocks)	See IEC 61508 (IEC, 1998) and IEC 61511 (IEC, 2001) for life cycle requirements and additional discussion		

Layer of Protection Analysis..., Wiley, CCPS, 2001

Layer of Protection Analysis (LOPA) References

- *Layer of Protection Analysis, Simplified Process Risk Assessment*, 2001, Wiley, American Institute of Chemical Engineers, Center for Chemical Process Safety, ISBN 0-8169-0811-7
- *Guidelines for Initiating Events and Independent Protection Layers in Layer of Protection Analysis* (soon to be released)
- *Guidelines for Enabling Conditions and Conditional Modifiers in Layer of Protection Analysis*, 2013, Wiley, American Institute of Chemical Engineers, Center for Chemical Process Safety



79

Layers of Protection Analysis (LOPA)

□ IPL Characteristics

- Is a device, system or action that is capable of preventing a scenario from proceeding to its undesired consequence independent of the initiating event or the action of any other layer of protection associated with the scenario.
- In order to be considered an IPL and “credited”, it must be
 - Effective
 - Independent
 - Auditable

80

Layers of Protection Analysis (LOPA)

□ Limitations

- Reliability data is limited
- Variability in consequence severity ratings
- Be careful with enabling conditions and conditional modifiers
- Be consistent

81

Layer of Protection Analysis (LOPA)

Typical Frequency Values, f , Assigned to Initiating Events

Initiating Event	Frequency Range from Literature (per year)	Example of a Value Chosen by a Company for Use in LOPA (per year)
Pressure vessel residual failure	10^{-5} to 10^{-7}	1×10^{-6}
Unloading/loading hose failure	1 to 10^{-2}	1×10^{-1}
BPCS instrument loop failure Note: IEC 61511 limit is more than 1×10^{-5} /hr or 5.76×10^{-5} /yr (IEC, 2001)	1 to 10^{-2}	1×10^{-1}
Regulator failure	1 to 10^{-1}	1×10^{-1}
Small external fire (aggregate causes)	10^{-1} to 10^{-2}	1×10^{-1}
Large external fire (aggregate causes)	10^{-2} to 10^{-3}	1×10^{-2}
LOTO (lock-out tag-out) procedure* failure *overall failure of a multiple-element process	10^{-3} to 10^{-4} per opportunity	1×10^{-3} per opportunity
Operator failure (to execute routine procedure, assuming well trained, untroubled, not fatigued)	10^{-1} to 10^{-3} per opportunity	1×10^{-2} per opportunity

Layer of Protection Analysis... Wiley, CCPS, 2000

LOPA

Example values

INDEPENDENT PROTECTION LAYER	PFD
Control loop	1.0×10^{-1}
Relief valve	1.0×10^{-2}
Human performance (trained, no stress)	1.0×10^{-2}
Human performance (under stress)	0.5 to 1.0
Operator Response to Alarms	1.0×10^{-1}
Vessel pressure rating above maximum challenge from internal and external pressure sources	10^{-4} or better, if vessel integrity is maintained (i.e., corrosion understood, inspections and repairs in place)

Layer of Protection Analysis (LOPA)

Date: 08/01/2009	Equipment: Scenario title: Cooling water failure with runaway reaction and potential for reactor overpressure, reaction, rupture, leakage, rupture, injuries, and fatalities. Agitation assumed.
Consequence: Runaway reaction and potential for reactor overpressure, reaction, rupture, leakage, injuries, and fatalities. Category 5	Probability: (per year)
Risk source category: Unacceptable (Greater than 10 ⁻³ per year)	1 x 10 ⁻¹
(Unacceptable risk is defined as greater than or equal to 10 ⁻³)	1 x 10 ⁻¹
Initiating cause: Loss of cooling water	1 x 10 ⁻¹
(Initiating event or condition)	0.5 (per reactor)
Human factors modifiers (if applicable): Probability that reactor in condition where runaway reaction can occur on loss of cooling (annual basis)	N/A
Independent protection layers (IPs): Probability of personnel in affected area	N/A
Human factors modifiers (if applicable): Probability of fatal injury	N/A
Independent protection layers (IPs): Other	N/A
Frequency of unmitigated consequence: 5 x 10 ⁻²	
Independent protection layers (IPs): Human action: Probability of personnel in affected area addition on BPCS loop high reactor temperature alarm	1 x 10 ⁻¹
Independent protection layers (IPs): Human action: Probability of personnel in affected area addition on BPCS loop high reactor temperature alarm	1 x 10 ⁻¹
Pressure relief valves: Probability of personnel in affected area addition on BPCS loop high reactor temperature alarm	1 x 10 ⁻¹
Pressure relief valves: Probability of personnel in affected area addition on BPCS loop high reactor temperature alarm	1 x 10 ⁻¹
SIF (Supplementary Protection Function): SIF to open vent valve (see Actions for design details)	1 x 10 ⁻¹
SIF (Supplementary Protection Function): SIF to open vent valve (see Actions for design details)	1 x 10 ⁻¹
SIF (Supplementary Protection Function): SIF to open vent valve (see Actions for design details)	1 x 10 ⁻¹
Notes: (Note: SIFs are not independent of the same operator already credited.)	
Notes: (Note: SIFs are not independent of the same operator already credited.)	
Total PFD for all IPs: 1 x 10 ⁻¹	
Frequency of mitigated consequence: 5 x 10 ⁻²	
Risk tolerance criteria (Health): Risk with added SIF	
Notes: Add SIF for all 3 reactors, isolat SIF with minimum PFD = 1 x 10 ⁻¹ for opening vent valves on high temperature. Separate nozzles and piping for each vent valve. Criteria: Consider piping and nozzles for potential for vessel integrity damage and common cause. Consider piping purges under all vent valves / PFDs. Responsible group / person / date: Plant Technical / J. Doe / January 2009	
Notes: Ensure SIFs are not dependent on the same operator already credited. Ensure RV design, installation, maintenance meet requirements for PFD 1 x 10 ⁻² as a minimum. If determined to be better, consider PFD for Vent Valve SIF PFD.	

CCPS Guidelines for Hazard Evaluation Procedures, Wiley, 2009

LOPA Example

■ Simplified Example

- Batch system
- 300 gallon reactor (100 psi MAWP) with rupture disk relief
- Heated with steam jacket
- Steam supply pressure 80 psi
- Steam flow controlled by steam control valve and internal vessel temperature
- Powder charge into water, then agitation
- Powder not combustible
- Runaway reaction initiation at 212 deg F, Pmax for runaway is 400 psi
- This is scenario used for basis of design for rupture disk


85 |

LOPA Example

- PHA Excerpt:

Item	Deviation	Causes	Consequences	Consequence Rank	Safeguards	Likelihood	Risk Number
4.6	High Temperature	4-1 fails low	High Pressure - runaway reaction resulting in vessel failure (Pmax > MAWP). Vessel in normally occupied area, multiple fatalities possible.	5	SD-1 sized for this scenario and routed to a safe location based on modeling.	E	TD

LOPA Example




Scenario Number	Equipment Number	Scenario Title:
Date:	Description	Probability Frequency (per year)
Consequence Description/Criteria		
Risk Tolerance Criteria (typically a frequency)		
Initiating Event (typically a frequency)		
Enabling Event or Condition		
Conditional Modifiers (if applicable)		
Probability of ignition		
Probability of personnel in affected area		
Probability of fatal injury		
Otherwise		
Frequency of Unmitigated Consequence		
Independent Protection Layers		
Safeguards(non-IPs)		
Total PFD for all IPs		
Frequency of Mitigated Consequence		
Risk Tolerance Criteria Met (Yes/No):		
Actions Required to Meet Risk Tolerance Criteria:		
Notes:		
References (links to originating hazard review, PFD, P&ID, etc.):		
LOPA analyst (and team members, if applicable):		

Process Hazard Analysis

Process Hazard Analysis (PHA)

The Process




What is Intended to Accomplish

- A Hazard is Inherent Physical or Chemical Characteristic that has the potential to harm
- The Revalidation is a study effort to identify and analyze the significance of hazardous situations to associated with a process or activity
- It's used to pinpoint weaknesses in the design and operation of facilities that could lead to accidental chemical releases, fires or explosions.
- It provides organizations with the information to help them improve the safety and manage the risk of their operations

Why?

Valero McKee Refinery Propane Fire

Why Use the CCPS Method?



Summary of The CCPS Steps

- Name The Team
- Notify Management
- Train the Team on the Basics and Why Revalidation Including Facility Tour
- Prepare for the Revalidation and Assemble PSI
- Evaluate the Prior PHA Study

Summary of The CCPS Steps

- Identify Changes that Have Occurred Since the Last PHA
- Identify the Appropriate Revalidation Methodology
- Conduct the Revalidation Study Sessions
- Document the Revalidation Study – Author the Report

Recommendation

**Start Early
Plan! Plan!**

It Takes Months

Let's Review Each Step



Name & Train the Team



Key Elements to Success

- Train on What the PHA Revalidation Process is Meant to Accomplish
- Train and Review the PHA Process That Will be Used – What If, HAZOP, FMEA
- Review the PHA Team Makeup

PHA Preparation

Name the Team

Name Your PHA Team

- Consider 5 to 7 team members optimum
- Team leader (facilitator) – hazard analysis expertise
- Engage Your Consultant Early (if using one)
- Scribe – responsible for PHA documentation
- Key members – should have process/ engineering expertise, operating and maintenance experience
- Supporting members – instruments, electrical, mechanical, explosion hazards, etc.

PHA Preparation

Process Overview & Tour

Process overview & Tour of Covered Process

- Prearrange for someone to give brief process overview, covering such details as:
 - Process, controls
 - Equipment, buildings
 - Personnel, shift schedules
 - Hazardous materials, process chemistry
 - Safety systems, emergency equipment
 - Procedures
 - What is in general vicinity of process
- Have plant layout drawings available
- Tour the Covered Process with the Team

Notify Management – Revalidation, What Is It?



Key Elements to Success

- The Reason for Revalidation
- Revalidation Objective & Concept
- Revalidation Schedule & Budget
- The Role of Management and the Team in the Revalidation Procedure

Prepare for the Revalidation & Assemble PSI



Key Elements to Success

- Preplan the Revalidation
 - Establish Scope
 - Select Team, Schedule
- Identify and Collect PSI
 - Determine PSI Requirements
 - Review and Confirm Boundary
 - Assemble & Distribute PSI to Team for Pre-Review

Key Elements to Success

- Review and Analyze PSI
 - Prior PHA Report and Related Information
 - Resolution Completion Report for Prior PHA Recommendations
 - MOC & PSSR Documentation – Critical
 - PSM Audit Results
 - Incident and Near Miss Reports
 - Piping & Instrumentation Diagrams (P&ID's)
 - Operating Procedures & Safe Work Practices

Process Safety Information Required for a PHA

<ul style="list-style-type: none">■ Materials of Construction■ Process Chemistry■ Reactive Chemistry Information – Kinetic Data■ Design Energy & Mass Balances■ Correct P&ID's■ Mechanical Integrity■ Relief Calculations■ Electrical Classifications■ Operating Procedures: Walked Down & Correct	<ul style="list-style-type: none">■ Codes & Specifications■ Vendor Drawings■ MOC Packages■ Incident/Accident Reports■ Special/Unique Design Specifications■ Maintenance Procedures■ Testing & Inspection Reports■ Ventilation Systems■ Safety Systems (SIL's)■ Emergency Procedures
--	--

Process Safety Information
Required for a PHA Revalidation

THE REALITY:
YOU MUST HAVE YOUR PSI
ASSEMBLED, OR...
YOU CAN'T DO AN
EFFECTIVE PHA

Evaluate The Prior PHA Study



Keys to Success

Evaluate the Prior PHA with Respect to
Essential Criteria


- PHA Rigor
- Methodology Used
- Team Make Up
- Documentation Used

Evaluate PHA Quality & Completeness


Realities We've Learned

- Many Initial and Prior PHA's Did Not:
 - Include Human Factors and Facility Siting
 - Include Evaluating Operation Procedures & Safe Work Practices
 - Identify the Appropriate Process Boundary
 - Use Complete or Correct PSI
 - Study the Hazards in Enough Detail

Many Times – Not Done



Most Times – Not Studied



Origin of Human Error

Todd Conklin Human Performance Training

Facility Siting-Not Properly Evaluated



Not Just This...



But This

Identify Changes that Have Occurred Since the Last PHA



What's Changed?

- Complete the Appropriate Section of the CCPS Revalidation Checklists on Changes: A Critical Step
 - PHA Quality & Completeness Checklist
 - Change Summary Worksheet
 - Facility & Process Modification Checklist
 - Facility Stationary Source Siting Checklist
 - Human Factors Checklist

Appendix C

PHA Quality and Completeness Checklist*

OBJECTIVE: To evaluate the prior PHA against quality and completeness criteria established by company and regulatory requirements. A "No" response to any item requires that the issue be adequately considered during the revalidation PHA study sessions.

Verification Questions	Yes No Maybe	evidence of compliance	Comments on Adaptivity of Compliance
ACCESS TO AND USE OF PROCESS SAFETY INFORMATION			
1. Is there evidence that the PSI was prepared and maintained in a manner that would be reasonable to expect to obtain recommendations generated to complete the PSM?			
2. Is there evidence that the PSI contained up-to-date PFDs?			
3. Is there evidence that unit procedures were available?			
4. Is there evidence that the PSI contained design and operating parameters for major equipment (e.g., vessels, heat exchangers, pumps)?			
5. Is there evidence that the PSI contained safety device design and setpoints data?			
6. Is there evidence that the PSI contained vessel system design data?			

⁴ This checklist is provided for illustrative purposes only. Readers may wish to develop such a checklist specific to their own situation and needs.

Appendix D

Example Change Summary Worksheet

OBJECTIVE: To record both controlled and uncontrolled changes identified during documentation reviews and interviews. Changes will be reviewed during PHA revalidation sessions.

Appendix E

Facility and Process Modification Checklist*

OBJECTIVE: To serve as an aid in identifying and recording changes that may have occurred in the process or facility. Changes will be reviewed during PHA revalidation sessions.

Facility Modifications	Response	Recommendations
1. Nine buildings, culvers, etc., been damaged or destroyed by fire. What facility would that likely be affected by a fire?		
2. Nine staffing levels changed since the previous year. What facility would be most likely to respond to emergency situations have diminished?		
3. Nine traffic patterns (e.g., new rail spur; new highway; new bridge) have been developed (e.g., the could the process be affected by a new resource source; can emergency response be more likely?)		
4. Has the organization's training program remained consistent with the one's been conducted since the previous PMS?		
5. Nine emergency preparedness practices remained substantially the same as those conducted since the previous PMS?		

* This checklist has been reproduced from Smith and Whittle (2000) and is provided for illustrative purposes only. Readers may wish to develop such a checklist specific to their own situation and needs.

Appendix F
**Facility and Stationary
Source Siting Checklist**

Item No.	Question	Response	Recommendations
I. Spacing Between Process Components			
1	Are operating units and the equipment within 100 feet of each other? Is potential damage from fires or explosions in adjacent areas?		
2	Are there safe exit routes from each unit?		
3	Has equipment been adequately spaced and located to withstand potential damage or performance (e.g., pulling heat exchanger bundles, dumping catalyst, or rupturing piping) in adjacent areas?		
4	Are vessels containing highly hazardous chemicals located sufficiently far apart if not, what hazards are introduced?		
5	Is there a safe and direct access for emergency vehicles (e.g., fire truck)?		
6	Can adjacent equipment or facilities withstand the overpressure generated by potential explosions?		
7	Can adjacent equipment and facilities (e.g., support structures) withstand flame propagation or radiation from potential fires?		
8	When provisions have been made for mitigating explosions in process components, are the vents directed away from personnel and equipment locations?		

Appendix G
Human Factors Checklist*

Item No.	Question	Response	Recommendations
I. Housekeeping and General Work Environment			
1	Are adequate signs posted near maintenance, cleaning, or storage areas to identify the area as a hot or cold area or hazardous area associated with the area?		
2	Are adequate barriers erected to limit access to maintenance, cleanup, or storage areas?		
3	Are working areas generally clean?		
4	Are personnel aware of the time that a worker spends in an extremely hot or cold area?		
5	Is noise maintained at a tolerable level?		
6	Are alarms audible above background noise both inside the control room and in the process area?		
7	Is there sufficient emergency lighting sufficient for all area operations?		
8	Is there adequate backup power for emergency lighting?		
9	Is the general environment conducive to safe job performance?		
II. Accessibility/Reliability of Controls and Equipment			
1	Are adequate supplies of protective gear readily available for routine and emergency use?		

* This checklist is provided for illustrative purposes only. Readers may wish to develop such a checklist specific to their own situation and needs.

What's Changed?

- Process changes have introduced new hazards or accentuated existing hazards
- Changes in on site or off site occupancy patterns that changed the at-risk populations
- New knowledge is now available to better understand the hazard potential, revealing potentially more severe consequences
- Actual incidents have revealed scenarios not previously identified in a PHA
- Safeguards previously credited in the PHA have been removed, compromised, or discredited.

Identify Revalidation Methodology



Keys to Success

- Revalidation Options
 - Update & Revalidate
 - Retrofit, Update & Revalidate
 - Redo
- Selecting the Revalidation Option

Conduct the Revalidation Study Sessions



Keys to Success


- Training – Covered Earlier
- Performing the Revalidation According to the Methodology Selected
- Special Considerations
 - Staying Productive
 - Facility Siting
 - Human Factors
 - Operating Procedures & Safe Work Practices
 - Wrap Up Discussions


Document the Revalidation Study




Keys to Success

- Documentation of Approach
- Documentation of Worksheets
- Author the Report
- Recommendation Documentation, Assignment and Follow up
- Records Retention and Distribution







PHA Revalidation Process

An Example Customized Process

- Why An Effective PHA is Necessary
- The PHA Re-Validation Process
- HAZOP Method Overview
- Overview of E Complex Process
- Overview of Last PHA Re-Evaluation
- Review Status of Audit Recommendations
- Review Status of Past PHA Recommendations
- Review Past E-Complex MOC's
- Review PHA Team Member's Change Checklist Results
- PHA Quality & Completeness Checklist Review
- Perform the PHA Revalidation Sessions
- Document the PHA Revalidation Study
 - Publish in Draft Form
 - Team and Management Review
 - Publish in Final Form
 - Assign Recommendation Responsibility and Track to Closure



PHA Revalidation Process

- PHA Re-Validation
- Final Review of Completed PHA's
- Review of PHA Recommendations Generated & Plan to Complete
- Next Steps – Preparing for the Report
- PHA Re-Validation Wrap Up

The Goal

An Effective PHA Revalidation
 Maintaining System Integrity
 Protecting the People

Let's Review An Example



Global Risk Management

Process Hazard Analysis Revalidation

GRM Chemical
Process Safety Management of Highly Hazardous and Explosive
Chemicals

Version 1.0
Last Edited: 3/1/14
Steve Davis
Process Consultant
GRM, Inc.

Table of Contents

Table of Contents	2
Objectives	3
Summary of the PHA Revalidation Methodology	4
PHA Documentation Reviewed	5
PHA Revalidation Team	6
PHA Validation Results	7
PHA Validation Results	8
Summary	9
Appendix A: Action Items List	10
Appendix II: PHA Quality & Completeness Checklist	11
Appendix V: Human Factors Checklist	12
Appendix VI: GRM PHA Revalidation Digital Documentation Addendum Directory	14

	<p>Objectives</p> <p>The objective of the Process Hazard Analysis (PHA) Revivalization is to reevaluate and combine the PHA's of the 1993, 1996, 1998, 2002, 2003, 2005, 2007, 2008, 2010, 2011, 2012, 2013, 2014, 2015, 2016, 2017, and 2018 PHA's. The combining of these PHA's and the addition of the qualitative analysis is at the recommendation of the U.S. Chemical Safety and Hazard Investigation Board (CSB) in their report titled "Review of Process Hazard Revivalization, the original 1993 and 1996 PHA's along with the 2007 and 2008 revivals were included in the development of this PHA. The 2010, 2011, 2012, 2013, 2014, 2015, 2016, 2017, and 2018 PHA's and all equipment, process modifications, operating instructions and safe work practices are properly studied.</p> <p>The process system is located in the City of Smyrna, Georgia.</p> <p>Process Boundary</p> <p>The covered process of the PHA Revivalization as the CRM Chemical Process involving IPA and the IPA Storage Tank and Fire Suppression System. The physical process boundary of the equipment include the following:</p> <ul style="list-style-type: none"> • IPA Chemical Process <ul style="list-style-type: none"> ◦ IPA condenser ◦ IPA pump ◦ IPA storage tank ◦ IPA Piping System Connected to Storage Tank ◦ All piping equipment, piping, control valves and instrumentation • IPA Storage Tank <ul style="list-style-type: none"> ◦ IPA Storage Tank ◦ IPA Storage Tank Fire Suppression System ◦ IPA Storage Tank Fire Suppression System ◦ IPA Process Heater System ◦ All piping equipment, piping, control valves and instrumentation <p>The PHA also included a reevaluation of the PHA for operating instructions or Standard Operating Procedures (SOP's) and Safe Work Practices related to the IPA Chemical and IPA Storage Tank and Undressing operators.</p>
--	--

Summary of the PHA Revivalization Methodology
<p>The following methodology was utilized for the PHA revitalization. The ACHme Center for Chemical Process Safety methodology for PHA revitalization was utilized to perform the revitalization. This process included the following steps:</p> <ul style="list-style-type: none"> • The team evaluated the documentation above to identify changes in the process equipment, design, operating procedures and safe work practice since the last PHA revitalization, (see documentation list in previous section). • The team completed the ACHme Center for Chemical Process Safety PHA revitalization checklist for the following areas to determine if any changes have occurred since last PHA revitalization or since original PHA was completed. • The team reviewed any safety systems design and management of change packages since last PHA. • Completed a new PHA worksheet for both Chemical Process and Piping Storage Tank as recommended by the ACHme Center for Chemical Process Safety. The new PHA worksheet included a quantitative risk analysis for each node and deviation based on a standard five risk matrix (Likelihood of Occurrence and Consequence of Occurrence) for each hazard, severity and detection. These values were multiplied to yield a Risk Priority Number (RPN). • This new PHA worksheet was based on the original 1992 and 1996 PHAs and the PHA revitalizations (2007 and 2010). • Based on the documentation reviewed and the new PHA worksheet completed, an action items list was developed and prioritized in accordance with the Risk Priority Number (RPN). • The action items list was provided to Mead Weeterville management for follow up action and completion. <p>Based on the review of information detailed above, and the quality and completeness of the previous PHAs and PHA revitalizations in addition to the February 2013 PHA audit recommendations, the GRM PHA revitalization team determined that the new PHA was complete and valid.</p> <p>The GRM PHA method of HACCP was used in the completion of the new PHA worksheet.</p> <p>The team also selected the digital management of this PHA revitalization and addendum documentation.</p>

PHA Documentation Reviewed
<p>The following documentation was reviewed in preparation for the PHA revalidation. This documentation is presented in separate sections as addendum to the report.</p> <p>Documents reviewed</p> <ol style="list-style-type: none"> 1. Application (PHA boundary for Chemical Process and P&I Storage) 2. Employee Participation Plan in written program 3. Hazardous Materials Inventory and locations 4. Technology and Experience in the Process (current and next market). P&ID's reviewed and walked down with the team 5. Mechanical Integrity documentation for vessels, relief systems, valves, etc. 6. PHA Audit - 3rd Party Audit and 2020 Revalidation 7. Facility Siting documentation 8. Management of Change changes since the last PHA revalidation and corresponding P&ID red material releases since last I&C 9. Documentation of the last I&C 10. Safe Work Practices for both Chemical Process and P&I Storage 11. P&I Drawings 12. PHA Audit - 3rd Party Audit performed Corporate GRM PSM Audit Team 13. PMS Audit 14. Facility & Process Modifications Checked 15. Facility & Process Modifications Source Checked 16. Human Factors Checklist <p>The documentation above was assembled in electronic form and studied by the team both before and during the PHA revalidation meeting. The documentation was also presented in hard copy format. All documentation packages were also assembled in the PHA revalidation meeting room for review by the team during the PHA revalidation meeting and the PHA validation.</p> <p>See the addendum sections in separate digital documents for documentation.</p>

PHA Revivalization Team	
The GRM PHA revitalization team consisted of the following team members:	
PHA Revivalization Facilitator:	Steve Davis, GRM
GRM Project Leader & Engineer:	John W. Johnson
Engineering:	David Johnson
PSA Processes:	Walter Johnson
HA Processes:	Heidi Schumakar
HA Processes:	Ray Morrison
Chemical Storage:	Alex Morrison
Chemical Storage:	Don Lasseter
Technology:	Jackie Smith
Safety:	Roy Rogers

PHA Validation Results	
Previous PHA Results	
The previous PHA results were reviewed and evaluated and found to be complete, but did not include the review of the new process flows and associated equipment. The previous PHA was conducted prior to prior operating practices (RAGAGEP) in addition to the internal February 2014 CRH PSD Audit recommendations. Additionally, additional areas were also identified in the new PHA workbooks including the following:	
<ul style="list-style-type: none">• New PSD boundary adjustments that eliminated past PHA nodes and deviations• New PSD boundary adjustments• Additional review of IPA Storage Tank	
These required revisions resulted in the decision to perform the Results, Update and Revalidate documentation.	
Documentation	
Status of previous PHA action items table	
All previous PHA action items have been addressed. Additionally, complete MCC packages have detailed changes in the IPA Chemical Process & Storage Tank processes.	
Post Incident Reports	
Post Incident Reports were evaluated. Incidents required a review of the IPA storage tank hazards and design as noted above.	
Management of Change Packages	
Review of MCC packages indicated that changes in the process have been well documented with MCC packages and the associated supporting MCCs for the CRH processes.	
Pre-Start Up Safety Review Documentation	
Review of the PSDS documentation indicated no changes since last PHA other than those documented in the MCC packages above.	
Operating Instructions	
New operating instructions have been recently developed for both CRH Chemical Process and IPA Storage operations. The operating instructions were developed as part of the new PHA re-validation. A recommendation was also developed to revise the current Chemical Process operating instruction.	
Current Process Safety Information (PSI) and P&ID's	
P&ID's were valid down, tall verified, red marked and re-issued in July 2014 and found to be current and reflect the actual processes.	

PHA Validation Results	
Facility Siting	Facility siting documentation was reviewed with no changes found since the last PHA. This study was also conducted by the completion of the facility siting checklist.
Hazard Factors Checklist	The pre-completion hazard checklist completed indicated no action items.
List of New Safety Systems	Only one new safety system was noted installed since the last PHA. This new safety system not classified as a instrumented system, but a pressure gauge on the IPA storage tank due to a possible over pressurization concern. The pressure gauge is located on the top of the IPA storage tank. The new safety system was placed on the IPA storage tank due to an air pump purging system for tank banking. This new safety system and the documentation was developed as part of the PHA revalidation with recommendations developed.
New Action Items List	New action items were developed as part of this PHA revalidation and are listed in the following sections of this report document. The action item list was developed as a result of the completion of the PHA revalidation checklist in addition to the PHA revalidation.

<p>Summary and Conclusions</p>
<p>The GRIM PSM team has worked diligently to update PS as a result of the recent PSM audit and also recent PSM issues communicated by members of the PSM team. The result is that process safety information is largely up to date.</p> <p>The PMS review methodology of <i>Review, Update and Resilience</i> was required due to the following:</p> <ul style="list-style-type: none"> • PSM Audit Recommendation dated February 2013 <ul style="list-style-type: none"> - Qualitative Analysis - Identification of deviations from PMS and PSM practices - New operating instructions for IPA Chemical Process and IPA Storage <p>Only one serious deviation was identified as part of the new PMS study involving the potential over pressurization of the IPA Storage tank. The deviation was identified by the PMS team and the PSM team with management of change actions already underway. In that the deviation condition was still occurring, a management of change was issued. The correction of the deviation was already underway and the conclusion of the validation.</p> <p>The GRIM PMS Resilience team would be complimented for their dedication, time allocation and attention to detail during the PMS review. The PMS team would also be complimented for their attention to the completeness of the documentation and attention to detail during the HAZOP process resulted in an effective PMS resolution.</p>

Addendum III: PHA Quality & Completeness Checklist			
Verification Question	Yes	Evidence of Compliance	Comments on Adequacy of Response
Overall Safety Information			
1. Is there evidence that the risk was correctly identified and assessed?	Yes	Comments on risk form and risk log	
2. Is there evidence that the risk was correctly prioritized, based on risk priority (RPLC)?	Yes	Comments on risk log	
3. Is there evidence that the risk was correctly communicated to the relevant stakeholders?	Yes	Comments on risk log	
4. Is there evidence that the risk is controlled (i.e., risk is reduced to an acceptable level) through the required (e.g., controls, lead, exchanges, transfers, etc.)?	Yes	Comments on risk log and in QCP's	
5. Is there evidence that the risk is communicated to the relevant stakeholders?	Yes	Comments on risk log	
6. Is there evidence that the risk is communicated to the relevant stakeholders in a timely manner?	Yes	Comments on risk log	
7. Is there evidence that the risk is communicated to the relevant stakeholders in a timely manner and the process for doing so is clearly defined?	Yes	Comments on risk log	
Control of the Risks			
1. Is all potential hazard (i.e., risk) responded to in the risk log (e.g., risk reduction, risk mitigation, etc.) associated with a measure of control (e.g., control measure, lead, exchange, transfer, etc.)?	Yes	Comments on risk log	
2. Is all relevant evidence (e.g., risk reduction, risk mitigation, etc.) associated with a measure of control (e.g., control measure, lead, exchange, transfer, etc.)?	Yes	Comments on risk log	
3. Is all relevant evidence (e.g., risk reduction, risk mitigation, etc.) associated with a measure of control (e.g., control measure, lead, exchange, transfer, etc.)?	Partial	Partial relevant evidence changes in QPs Partial relevant evidence changes in QPs Changes in boundary required revision to control measure	
4. Is there evidence that the risk is controlled?	Yes	Comments on risk log	
5. Is there evidence that the risk is communicated to the relevant stakeholders?	Yes	Comments on risk log	
6. Is there evidence that the risk is communicated to the relevant stakeholders in a timely manner?	Yes	Comments on risk log	
Communication of the Risks			
1. Is there evidence that the risk has been communicated to the relevant stakeholders?	Yes	Comments on risk log	
2. Is there evidence that risk messages were tailored to the needs of the audience?	Yes	Comments on risk log	
3. Is there evidence that risk messages were tailored to the needs of the audience?	Yes	Comments on risk log	
Completion of the Risk Assessment			
1. Does the PHA report information for each risk that is relevant to the project objectives identified?	Yes	Comments on risk log	

Addendum IV: GRM PHA Revitalization Digital Documentation Addendum Directory

There are 78 More Pages of Worksheets

PHA Revalidation Process

- Pre-PHA Revalidation Documentation Assembly
- Pre-PHA Revalidation Documentation Review
- Assembly of PHA Team
- Schedule PHA Revalidation
- Name a Scribe
- Complete CCPS PHA Revalidation Checklists
- Determine PHA Revalidation Method
- Perform PHA Revalidation / PHA Worksheet Completion
- PHA Review of PHA Recommendations Generated & Plan to Complete
- Prepare PHA Revalidation Report & Submit to Team for Review
- PHA Re-Validation Report Finalizing & Publishing
- Establish Action Plan for Recommendations

Process Safety Management of Highly Hazardous & Explosive Chemicals



Management of Change 29CFR1910.119(l)

What if Our PHAs (or a project, or just a random idea) Reveal the Need to Change Something?

We Must Use Management of Change (MOC)

Management of Change

1910.119(l)

The employer shall establish and implement written procedures to manage changes (except for "replacements in kind") to process chemicals, technology, equipment, and procedures; and, changes to facilities that affect a covered process.

Management of Change - Why?

- Many of the catastrophic accidents over the past few decades can be traced, in large part, to a management of change system that was not in place or was not functional (e.g., Flixborough, Bhopal).




Case Study: Flixborough

- Vapor cloud explosion - fueled by release of 30 tons of cyclohexane
- Largest single loss by fire or explosion in the United Kingdom
 - killed 28 people
 - injured 89 others
 - \$63 million in property damage




MOC Cause: Temporary Modification



Why did the Bypass Piping Fail

- No safety review and inadequate supervision
- Job was beyond professional capabilities of the workers
- Only drawing was a full-size sketch in chalk on the workshop floor.
- No one understood the forces that would be imposed on the pressurized piping



What Was Learned?

- A proper MOC procedure could have prevented this accident.
- One of main recommendations from inquiry
 - Any modification should be designed, constructed, tested, and maintained to the same standards as the original plant.

Failures in MOC

- Vapor cloud explosion and major fire within a refinery
 - 7 deaths
 - 13 injuries
 - \$35 million in losses (half in property damage, half in business interruption)
- Cause: Hidden Change to a valve



Failures in MOC

- Storage tank containing flashing, flammable fluid.
- Tank was connected to process unit via 10" line
- Corrosion attacked valve bonnet bolts and weakened them.
- Bonnet was blown off and an uncontrolled, catastrophic release occurred.



Can Changes Affect Everything in Our Program?

■ Might Affect:

- Process Information
- Process Toxicity
- Technology of the Process
- Equipment in the Process
- Mechanical Integrity
- Inspection & Testing
- Quality Assurance

■ Might Affect:

- PHAs
- Operating Procedures
- Safe Work Practices
- Training for Both Employees & Contractors
- Compliance Audits

Basically....Everything!

Management of Change (MOC)

Management of Change (MOC) is a process for **evaluating** and **controlling modifications** to facility design, operation, organization, or activities – *prior to implementation* – to make certain that **no new hazards are introduced** and that the risk of **existing hazards** to employees, the public, or the environment are **not unknowingly increased**.



CCPS Guidelines for Management of Change for Process Safety, Wiley, 2008

Management of Change (MOC)

▫ MOC is one of the most important elements of process safety

- MOC has been called a minute-by-minute risk assessment control system in plants and companies.
- It affords the opportunity to review changes which occur after the PHA has been completed. In fact, some changes are large or complex enough to require a PHA in and of themselves.
- A change is any modification to process chemicals, technology, equipment, or procedures and changes to facilities that affect a covered process except for replacement in kind (satisfies the design speciation).

CCPS Guidelines for Management of Change for Process Safety, Wiley, 2008

Management of Change (MOC)

□ Summary of Requirements

- Written Program – “Written procedures to manage changes to process chemicals, technology, equipment, and procedures; and changes to facilities that affect a covered process”
- Considerations must address:
 - Technical basis for change (*why the change is desired*)
 - Safety and health impacts
 - Modifications to procedures
 - Necessary time period for the change (*duration for temporary changes*)
 - Authorization requirements for the proposed change
- All potentially affected employees and contractors must be informed of and trained in the change prior to the change
- PSI, procedures, or practices must be updated accordingly
- Exempts “replacements in kind”

MOC Application

- Management of Change should be Completed on BOTH:
- Temporary
- Permanent Changes



MOC

Replacement in Kind

- A replacement that satisfies the design specifications.
- Examples
 - raising reactor temp. within safe operating envelope
 - replacing equipment or piping meeting the same specifications as the original



Emergency MOC Procedures

- Program must manage Emergency Changes
- Should set limits for when allowable and how authorizations will be obtained
- “Paperwork” must follow very closely behind



Management of Change

- Important March 31, 2009 Letter From OSHA:
“Some organizational changes such as changes resulting from mergers, acquisitions, reorganizations, staffing changes or budget revisions, may affect PSM at the plant level and would therefore trigger a PSM MOC procedure”

Management of Change (MOC) Pre-Modification Issues

- Check codes, standards, internal engineering specifications
- Complete design review
- Perform reactivity testing for new substances
- Add materials to TSCA/SARA inventories
- Complete safety and health impact review
- Comply with safety and loss prevention requirements

Remember all the Codes We Have Already Discussed

Management of Change (MOC) Pre-Modification Issues


- Complete maintenance review/review spare parts list
- Evaluate change against vent, relief, and flare capability
- Complete industrial hygiene review
- Review change against existing environmental permits
- Obtain required approvals
- Complete training on change for affected employees*
- SOPs marked-up
- P&IDs, PFDs, plot plans and other affected Process Safety Information (PSI) marked-up

Management of Change (MOC) Post-Modification Action Items


- Complete Pre-Start Up Safety Review (PSSR)
- Complete training on change for affected employees*
- SOPs issued effective
- P&IDs, PFDs, plot plans and other affected Process Safety Information (PSI) updated
- Training program modifications identified
- Preventive maintenance program modifications identified
- Mechanical Integrity information/files/records CMMS updated

Management of Change (MOC)

□ Generic MOC Process



CCPS Guidelines for Management of Change for Process Safety, Wiley, 2008



What Type of Stainless? What type of Nozzle?

Management of Change (MOC)
To MOC or not to MOC? Class Exercise

1. You need to change the set point of a relief valve. MOC or no MOC?

Yes – this is a process control change outside of established limits

2. You are changing a solvent used to clean and flush piping in the covered process. MOC or no MOC?

Yes – there could be material of construction issues (corrosivity, material/process compatibility, etc.)

Management of Change (MOC)
To MOC or not to MOC? Class Exercise

To MOC or not to MOC? Class Exercise

3. You are replacing an ASME code vessel with an API code vessel.

Yes – this is a code and application change although the design may be similar.

4. You are substituting an identical process chemical from another supplier.

It Depends

5. You are upgrading a section of pipe from carbon steel to stainless steel.

Yes – process material could be more corrosive to stainless than carbon steel. This is a change in equipment

Management of Change

Summary

PSM Documentation - Technology Use

Process Safety Management of Highly Hazardous & Explosive Chemicals



Pre-Start Up Safety Review (PSSR) 29CFR1910.119(i)

PSSR- Why?

Pre-Start Up Review

- The employer shall perform a pre-startup safety review for new facilities and for modified facilities when the modification is significant enough to require a change in the process safety information.



Pre-Start Up Review

- The pre-startup safety review shall confirm that prior to the introduction of highly hazardous chemicals to a process
- Construction and equipment is in accordance with design specifications
- Safety, operating, maintenance, and emergency procedures are in place and are adequate

Pre-Start Up Review

- For new facilities, a process hazard analysis has been performed and recommendations have been resolved or implemented before startup; and modified facilities meet the requirements contained in management of change
- Training of each employee involved in operating a process has been completed.

Pre-Start Up Safety Review

- Must be specific for the covered process
- May require additional programs other than Lockout Tagout, Line Opening & Hot Work...such as Confined Space, Electrical Safe Work Practices, Combustible Dust

Process Safety Management of Highly Hazardous & Explosive Chemicals



Process Hazard Analysis 29CFR1910.119(e)

The Goal

An Effective PHA Revalidation Maintaining System Integrity Protecting the People